

CCCF Sprinkler System Inspection

NFPA 25 requirements

Annual inspection requirements :

1. Hanger/ braces/supports 5.2.3
2. Hydraulic design informational sign 5.2.5
3. Information sign 5.2.7; 5.2.8
4. Pipe and fittings 5.2.2
5. Sprinklers 5.2.1.1
6. Dry pipe valves/quick-opening devices; interior 13.4.5.1.4
7. Hose connection pressure-regulating devices 13.5.2.1
8. Hose rack assembly pressure-regulating devices 13.5.3.1

5 Year inspection requirements:

1. Check valves; interior 13.4.2.1
2. Dry pipe valves/quick-opening devices; strainers, filters, orifices 13.4.5.1.5
3. Deluge valve; strainers, filters, orifices 13.4.4.1.5
4. Deluge valves ; interior 13.4.3.1.4
5. Preaction valves; interior 13.4.3.1.4
6. Preaction valves; strainers, filters, orifices 13.4.3.1.5
7. Alarm valves; interior 13.4.1.2
8. Alarm valves; strainers, filters, orifices 13.4.1.2